GAS SAFETY CERTIFICATE

This form can be used as a Landlord's gas safety certificate

Page 2 of 2. Ser No. 049913

198524.
Enter Company Registration Number

Engineer [redacted]
Gas Safe [redacted]
Engie Office Address ILA. ENGLISH HUB. SHEFFIELD. S10 3EA.

Contract Number
Customer Name MILLSTONE APP C/K
Site Address 50 ENDCLIFF VALE ROAD
Postcode S10 3AL.
Received By NO ONE. Signature

Landlords Details If Different
Name
Address
Postcode
Rented Accommodation YES/NO

App	Landlords appliance Yes/No	Service Inspection Repair	Appliance Details: Location	Type	Model	Serial Number	Burner Manufacturer	Flue Type (OF/RS/FL)
1	YES	SERVICE	PLANT ROOM	BOILER 3	VITODENS 200-W WB2B	7373/1080 1933/02	VIESSMANN	RS.
2								
3								
4								

General Safety Checks	Result	General Safety Checks	Result
Gas booster/compressor operating correctly (Yes /No/NA)	NA	Flue termination satisfactory (Yes/No/NA)	YES
Is there a current gas installation line diagram at primary meter (Yes/No/NA)	YES	Has a tightness test been carried out from local isolation valve (Yes/No/NA)	YES
Is the meter installation correct (Yes/No)	YES	Is gas pipework electrically bonded (Yes/No)	YES
Gas installation pipework adequately supported (Yes/No)	YES	Are adequate emergency isolation valves fitted (Yes/No)	YES
Gas installation pipework sleeved and sealed as appropriate (Yes/No)	YES	Are emergency valve handles in place and labelled (Yes/No)	YES
Is gas pipework colour coded or identified (Yes/No/NA)	YES	Do valves fail to the correct position (Yes/No)	YES
Is flue system installed in accordance with standards (Yes/No)	YES	Area clear of combustible materials (Yes/No)	YES

Ventilation

Low level free area cm² ~~or ventilation flow rate in m³/hr~~ Actual 1150 Required (Calculated) 1510

High level free area cm² ~~or ventilation flow rate calculated~~ Actual 1001 Required (Calculated)

All ventilation grills clear and unobstructed (Yes/No) Fans and/or flue interlocks operating correctly (Yes/No/NA)

Details of any faults	Remedial Action Taken	Comments and calculations
PCB BOARD BROWN	FITTED NEW PCB.	PARTS WARRANTY.
PUMP SEIZED UP	FREED OFF.	

Appliance Checks	App 1 or App 1 High	App 2 or App 1 Low	App 3 or App 2 High	App 4 or App 2 Low
Flue flow test satisfactory (Yes/No/NA)	NA	NA		
Spillage test satisfactory (Yes/No/NA)				
Air/Gas switch operating correctly (Yes/No/NA)				
Flame proving devices operating correctly (Yes/No/NA)				
Burner lock out time (seconds)				
Temperature and limit thermostats operating correctly (Yes/No)				
Heat net input rating data (kW)				

	App 1 or App 1 High	App 2 or App 1 Low	App 3 or App 2 High	App 4 or App 2 Low
Gas burner pressure (mbar) or heat input kW/h required				
Gas burner pressure (mbar) or heat input kW/h measured				
Gas rating measured (kW/h / NA)	59.6	19.08		
Air/gas ratio control setting (%/NA)				
Net flue gas temperature (gross less ambient) (°C)				
Oxygen (O_2 %)				
Carbon Monoxide (CO)(ppm)				

	App 1 or App 1 High	App 2 or App 1 Low	App 3 or App 2 High	App 4 or App 2 Low
Carbon Dioxide (CO_2) (%)				
Excess Air (%)				
CO/CO_2 Ratio				
Gross Efficiency (%)				
CO flue dilution (ppm)				
Standing pressure (mbar)				
Working pressure (mbar)				
Is appliance safe for use (Yes/No)				

Has a warning advice notice been raised (No or Warning notice Ser No or No's)	NOT WORKING.
Test Instrument	KANE 458
Test Instrument serial number	12172601

Worksheet No (if used)	
Checked by (office use)	
Entered on database	

Declaration of gas safety - I confirm that all of the above work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation and use) regulations, standards and procedures.

Date 08-07-22

Signature [redacted]

Service Centre, Pink - Site, Green - Engineer